



SFR166 Fire Extinguisher Certificate

108072 / Jamaica Street (1) / Day Centre, Bristol,
Bristol / BS2 8JP / Riverside / 29 Mar 2023

Complete

Site conducted	Riverside
Address	Jamaica Street (1) / Day Centre, Bristol, Bristol
Postcode	BS2 8JP
Job no:	108072
Date:	29 Mar 2023

Inspection

Details of work requested / carried out

Full extinguisher service.
Site is missing
6x blanket signs
2x fire blankets
1x wet chem sign

PASS/FAIL ELEMENT AND RECOMMENDATIONS

6x blanket signs
2x fire blankets
1x wet chem sign

Is the service complete?

Yes

Declaration

The Fire Extinguisher Maintenance has been carried out in accordance with BS5306 part 3. The Fire Blanket Maintenance has been carried out in accordance with BS EN18

I can confirm that the work detailed above has been completed satisfactorily in accordance with my instructions and agree to pay the total charge submitted for the work detailed on this worksheet. I confirm that I am authorised to sign on behalf of the client.

Engineer (Name and Signature)



Lajos Alsoszentivanyi
29 Mar 2023 1:26 PM UTC